

REPAIR REQUEST LIST

4651 N Daydream Ln
04/02/2024 4:54 pm

3.2.1 - Exterior: Driveway, Walkways & Patio CRACKS IN PATIO

Repair - Replace - Not Working

There are common cracks in the patio that would not necessarily need to be serviced.

Location
Rear



3.5.1 - Exterior: Exterior Siding Notes DAMAGED SIDING

Repair - Replace - Not Working

One or more sections of siding were damaged or deteriorated. Recommend repairs.

Location
Rear



3.5.2 - Exterior: Exterior Siding Notes
EXTERIOR VENTS NEED REPAIR

Repair - Replace - Not Working

The vent is missing or damaged and is in need of repair or replacement.




3.9.2 - Exterior: Exterior Doors
SLIDING DOOR DOES NOT LOCK

Repair - Replace - Not Working

The sliding glass door handle doesn't lock. Recommend repair.

Location
Rear



5.3.1 - Garage(s): Garage Door & Hardware
SEAL LOOSE

Repair - Replace - Not Working


The garage door seal is slightly loose. Recommend securing.



5.7.1 - Garage(s): Garage Side Door
HARDWARE NEEDS WORK

Repair - Replace - Not Working

The side door hardware (deadbolt/latch) to the garage is not working properly. Recommend repair.



15.9.1 - Interior: Fireplace
DID NOT WORK

Repair - Replace - Not Working

The fireplace did not respond to normal controls. Further evaluation or demonstration is recommended.



15,13.1 - Interior: Outlets, Electrical

EXPOSED WIRING

— Repair - Replace - Not Working

The wiring is exposed and outside a conduit. This is important to help prevent damage. Recommend repair.

Location

Basement

